



Cat. Code	Dimensions
	D(mm)
M309SEW1LED...	320
M309MEW1LED...	360
M309LEW1LED...	420
M309XLEW1LED...	450



- 
- 1- For proper utilization of this product and safety, it is mandatory to closely comply with the directions and notes in this instruction and guide.
 - 2- Earth connection as provided is mandatory.
 - 3- When various power loads exist, a separate switchboard including all protective equipment should be considered for the lighting system.
 - 4- During any construction process such as welding, etc., make sure that the luminaires are switched off or a stabilizer is used to prevent power disturbances leading to serious damage to the drivers or other electrical components.
 - 5- Serious damage in electrical components will be caused by applying inappropriate voltage.
 - 6- When carrying out maintenance works on the luminaire, ensure that the sealing gaskets are in proper condition and IP is preserved.
 - 7- If a luminaire has a specified Ingress Protection rating, protection devices such as glands, etc., should be used to provide the desired IP.
 - 8- Do not stare at LED light source.
 - 9- Do not directly touch or impact LED module.

Pendant mount

