


7002011813


www.megalite.com info@megalite.com




- 1- Do not directly touch or impact LED module.
- 2- Do not stare at LED light source.
- 3- Earth connection as provided is mandatory.
- 4- For proper utilization of this product and for safety, it is mandatory to closely comply with the directions and notes in this installation and maintenance guide.







M470...



M472...





M467...




Guide line and the earth label must be aligned while connecting the adaptor to the single pole rail.

Guides A and B must not be aligned while connecting the adaptor to the 3 poles rail.



Select the desired phase by rotating the graded switch



EN Instruction for installation and utilization of **NOVATRON** track light with adjustable light distribution




7002020304

www.megalite.com info@megalite.com





- 1- Do not directly touch or impact LED module.
- 2- Do not stare at LED light source.
- 3- Earth connection as provided is mandatory.
- 4- For proper utilization of this product and for safety, it is mandatory to closely comply with the directions and notes in this installation and maintenance guide.






Guide line and the earth table must be aligned while connecting the adaptor to the single pole rail.

Guides A and B must not be aligned while connecting the adaptor to the 3 poles rail.




Select the desired phase by rotating the graded switch


Angle adjustment luminaire




M+464...G460STRACKWR4...

M+464...G464STRACKJBD...






G460STRACKWR410-W
G460STRACKWR420-W








EN

Instruction for installation and utilization of surface mount single- pole track for **NOVATRON**, **LUMERIA** and **HONEY** track light



G464STRACKJBD100-W
G464STRACKJBD200-W



Grounding tab of the connector must be placed on the two copper side of the rail.





7002024005

www.megalite.com info@megalite.com

Megalite
Crafted for Brilliance

7002019807

www.megalite.com info@megalite.com



Cat. Code	L(mm)	L1(L2>8000)
G460NKSU	-	4000-6000
G460NPSKIT	-	4000-6000
GNPS60-Bracket	650 ±5	4000-6000
GNPS120-Bracket	1250 ±5	4000-6000

